Ottappalam Municipality

Date: 01/02/2021

## **CERTIFICATE**

Certified that in the public health point of view, the health and sanitation facilities arranged in the institution Amritha Vidyalayam, Ottappalam are found satisfactory.

This certificate is issued only to produce before CBSE authorities to renew affiliation.



Ottappalam Municipality

OTTAPALAM

KANNIAMPURAM, OTTAPALAM-679 104.





Mundur (PO), Palakkad (Dist.), Kerala 0491-2832663, 2832324, 9188183296 mail@irtc.org.in

www.irtc.org.in

## **ENVIRONMENT LABORATORY**

Approved by: Kerala State Pollution Control Board Approval No.: PCB/CL/RL/34/2021

No. IRTC/311/ENVL/ WS331/22

WATER OHALITY AMALYCIC D

Sample received from .	Location/Project Name	Date of receipt	Source of
Principal Amrutha School Kanniyampuram Panamanna Road, Ottapalam		08/04/2022	sample Open Well
		Sample No	Date of report
		WS 331	13/04/2022

Sl. No	Parameter	Unit	Test Result	BIS Limit For Drinking Water
1	pH	<u>-</u>	6.9	6.5-8.5
2	Colour	Hazen	-	-
3	EC	μs/cm	185	_
4	TDS	ppm	109	500
5	Turbidity	NTU	0.18	05
6	Alkalinity	mg/L	50	200
7	<sup>+</sup> Chloride	mg/L	7.1	250
8	Hardness	mg/L	58	200
9	Calcium	mg/L	12.8	75
10	Magnesium	mg/L	6.3	30
11	Fluoride	mg/L	0.25	1.0
12	Iron	mg/L	0.08	0.3
13	Sulphate	mg/L	3.2	150
14	Nitrate	mg/L	* 1	45
15	Total Coliform	MPN/100 ml	Absent	Absent
16	E.coli	<u>.</u>	Absent	Absent

Tested in accordance with: APHA, AWWA, WEF 2017

 EC - Electrical Conductivity, TDS - Total Dissolved Solids, NTU unit, MPN- Most Prol**PAINCIPAL**er, µs-Micro siemens, BIS-Bureau of Indian Standards, mg/L- millig

• Coliform & E.coli should not be present in 100 ml of sample as

AMRITA VIDYALAYAM **SOUTH PANAMANNA ROAD** ess manusaruram offaralam-679 104.

Disclaimer: The sample was taken and brought to the lab by the p IRTC.

Kavyakrishna M R Microbiologist

Head, Laboratory

WHE NOW PRO 43A d

Administrative Officer Integrated Rural Technology Centre Mundur, Patakkad

OTTAPALAM!